

Government of Bihar
Public Health Division Bettiah
Water Quality Testing Report


Received Sample on date : 15.10.2025


District -West Champaran				Testing date - 15/10/2025												Sample Collected by : School Staff
SL. No.	Block	Location of Source	Type of Source	Parameters tested												
				pH	Turbidity	Total hardness	Calcium	Magnesium	Chloride	Alkalinity	Iron	Nitrate	Sulphate	Fluoride	Arsenic	Total Coll.
1	Narkatiaganj	St. Xavier's High School, Krishi Bazar, Narkatiaganj	Boring water	-	1	264	72.8	20	30	304	0.18	3.20	8	0.74	-	< 1.1
Desirable Unit				6.5 - 8.5	1	200	75	30	250	200	0.3 mg/l	45 mg/l	200	1.00	0.01 mg/l	-
Maximum Permissible limit in absence of alternate source				NR	5 NTU	600 mg/l	200 mg/l	100 mg/l	1000 mg/l	600 mg/l	1 mg/l	NR	400 mg/l	1.5 mg/l	NR	-

Memo No. - PIAED/10/25 Bettiah, Dated - 15/10/2025
Copy to Principal St. Xavier's High School, Narkatiaganj to inform regarding reference to his letter No. - SXHS/78/2025

Dated :- 15/10/2025


Lab Assistant


Chemist


Executive Engineer

P.H. Division, Bettiah

**EXECUTIVE ENGINEER
P H DIVISION
BETTIAH(BIHAR)**